

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7160-1422:101 Page 1 of 1

CATEGORY: Cables-Conductor

LISTEE: Alfex Corporation, 2630 El Presidio Street, Long Beach, CA 90810
Contact: *Richard Temblador (310) 886-8300

DESIGN: ALFLEX aluminum and steel metal clad cables in *No. 18 AWG to 2000 MCM copper or *No. 12 AWG to 2000 AWG aluminum employing interlocked aluminum, or zinc-coated steel armor. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NEC Article 334, and applicable codes and ordinances.

MARKING: Listee's name, size and UL label.

APPROVAL: Listed as aluminum and steel metal clad cables for use in fire-resistive assemblies.

*02-27-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 28, 2002**

*Listing Expires **June 30, 2002***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager